Annexure C

PROFORMAFORSAFEDRINKINGWATERANDSANITARYCONDITIONCERTIFICATE

No. TC16950260000000064 Dated: 29\09\2026

Itiscertifiedthataninspectionteamheadedby..Er. Pramod Kumar (Assistant Engineer)

(Name of Officers with designation) from

...Uttar Pradesh Jal Nigam (Rural), Sultanpur.....PHEDinspectedt

The - Divya Diksha Institute, Dhaurahara, Sultanpur....(Name & Address of the school) on 29\09\2026.....(date of inspection) and on the basis of Water Test Report (Attached) bearing no..TC16950260000000064 dated.29\09\2026.. of

...District Level Water Analysis Laboratory, Uttar Pradesh Jal Nigam (Rural), Sultan pur.

.....(PHEDLab)certifiedthat the..Divya Diksha Institute.....(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

Thiscertificateisvalidtill...01 year. (29.09.2026 – 28.09.2027)

Signature with Seal: ...Pramod.....

Name : ...Pramod Kumar.....

Designation : Assistant Engineer

Name&Address oftheOffice/ Department

सहायक अभियन्ता
खण्ड कार्यालय
उ0प्र0 जल निगम (ग्रामीण)
सुलतानपुर

To

...Divya Diksha Institute

Dhaurahara, Sultanpur.....

(Name&Addressoftheinstitution)

Note:Thecertificateistobeissuedbyauthorizedofficer/PHEDLab/localbodies

Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural),
Saurmau, Sultanpur-228001

TC-16950

Rept No	Chemical Test/726/2026-2027	Date	29/09/2026	1	Page 1/1

ULR No- TC169502600000064I

Customer Details

Office Name and Address	**Divya Diksha Institute, Dhaurahara, Sultanpur (U.P.) 222303**
Ref Letter No & Date	Date 26-09-2026

Basic details of sample

District	Sultanpur	**Block**	P P Kamaicha
Gram Panchayat	Dhaurahara	**Village**	Dhaurahara
Habitation	NA	**Location**	
Water Source	R.O. Water	Sample No.	726
Quantity of Sample	1000 ml	Date of Sample Collection	25/09/2026
Receving Date	26/09/2026	Sample Collector	By Customer : Yogesh Chandra Pandey
Sample Depositer	By Customer : Yogesh Chandra Pandey	Sampling Method Used	NA
Analysis Start Date	26/09/2026	Analysis Completion Date	26/09/2026

Environmental Condition

Temperature	25±3 oC	Humidity	50±15%

Technical Data of Analysis

S. No.	Parameter	Units	Observed Value	Specified Values as per		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Turbidity	(NTU)	0.93	1.00	5.00	IS 3025 (Part 10) : 2023
2	pH	-	6.86	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2012 (RA :2022)
3	TDS	(mg/L)	108	500.00	2000	IS 3025 (Part 16) : 2023
4	Fluoride	(mg/L)	<0.1	1.00	1.5	APHA 24th Edition -4500 -F Method C (Electrode Method) : 2023
5	Iron	(mg/L)	<0.1	0.30	1	APHA 24th Edition-3500-Fe Method B(Phenanthroline Method):2023
6	Sulphate	(mg/L)	14.42	200.00	400	IS 3025 (Part 24) : 2009 (RA: 2022) / APHA 24th Edition -4500- SO4 Method E(Turbidimetric Method):2023
7	Nitrate	(mg/L)	1.20	45.00	45	APHA 24th Edition -4500-NO3 Method B (UV Screening Method):2023
8	Chloride	(mg/L)	27.99	250.00	1000	IS 3025 (Part 32) : 2025
9	T. Alkalinity	(mg/L)	40	200.00	600	IS 3025 (Part 23) : 2023
10	T. Hardness	(mg/L)	80	200.00	600	IS 3025 (Part 21) : 2009 (RA :2023)
11	Calcium	(mg/L)	14.42	75.00	200	IS 3025 (Part 40) : 2024
12	Magnesium	(mg/L)	10.56	30.00	100	IS 3025 (Part 46) : 2023
13	Taste	Qualitative	Agreeable	-	-	IS 3025 (Part 08) : 2023
14	Odour	Qualitative	Agreeable	-	-	IS 3025 (Part 05) : 2018
15	Colour	Hazen	5	5	15	IS 3025 (Part 04) : 2021

Note:

1. This Certificate refers only to the particular sample submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head Of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Prepared By

(Rukumkesh Verma)
Lab Technician

Authorised Signatory

Ram Badan Yadav
(Technical Manager)

Technical Manager
District Level Water Analysis Laboratory
Sultanpur UPJN

** End of Test Report**

Contact details - Email-upjnsln44lab@gmail.com Mob- 8382822001